

April 2022 – Important Information about your Drinking Water (Updated January 2023):

As required by the New Jersey Department of Environmental Protection (NJDEP), we are providing this update. The test result received for samples collected on January 19, 2023 for PFOA at the Beverly Road Water Treatment Plant was 11 parts per trillion (PPT). Since exceeding the NJDEP Maximum Contaminant Level (MCL) of 14 PPT for PFOA with the 1<sup>st</sup> quarter 2022 result, the running annual average (RAA) for PFOA at the Plant has ranged from 14 – 15 PPT. The Township's engineering consultant, T&M Associates, has prepared plans and specifications for ion exchange treatment system equipment that will bring the plant back into full compliance. Additional updates will be posted quarterly. For more information, please contact Scott Hatfield, Township Engineer at 609-239-5836 or [shatfield@twp.burlington.nj.us](mailto:shatfield@twp.burlington.nj.us).

This update is being provided by the Burlington Township Water Department

State Water System ID#: NJ0306001

Date posted: January 30, 2023